

**INDEPENDENT TESTING LAB**

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

Company: VILLAGE OF KALKASKA
Name:
ClientProj: MONTHLY
GTA ProjNo: 010422-2

Site Addr: 1005 ISLAND LAKE RD
KALKASKA
Sampled By: BRENDON WOLF/VOK
Date Rec: 1/4/2022
Time Rec: 11:54 AM

Sample No.	Sample ID	Date Sampled	Time Sampled	Sample Matrix
1	INFLUENT	1/4/2022	7:19 AM	WATER
2	EFFLUENT	1/4/2022	7:18 AM	WATER

ELECTRONIC SIGNATURE REPORT. This is a final report for the following pages of data for the samples specified above. All analysis was performed by the methods stated and all quality control measures required were completed. All quality control information is available upon request.

Kirk Chase

Kirk L. Chase/Chemist
Grand Traverse Analytical
830 Robinwood Court
Traverse City, MI 49686
Ph: 231-929-0905
Fx: 231-929-0894
SP: 231-590-0291
kirk@gtanalytical.com



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY:	VILLAGE OF KALKASKA	GTA PROJECT NO:	010422-2
PROJECT NO:	MONTHLY	GTA SAMPLE NO:	1
LOCATION:	1005 ISLAND LAKE RD	DATE RECEIVED:	1/4/2022
	KALKASKA	TIME RECEIVED:	11:54 AM
	MI	DATE SAMPLED:	1/4/2022
		TIME SAMPLED:	7:19 AM
SAMPLED BY:	BRENDON WOLF/VOK	SAMPLE MATRIX:	WATER
SAMPLE ID:	INFLUENT		

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
AMMONIA-N EPA 350.1	35	0.15	mg/L (PPM)	KC	1/4/2022
TOTAL PHOSPHORUS EPA 365.2	6.2	0.050	mg/L (PPM)	KC	1/4/2022

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED

**INDEPENDENT TESTING LAB**

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY: VILLAGE OF KALKASKA
PROJECT NO: MONTHLY
LOCATION: 1005 ISLAND LAKE RD
KALKASKA
MI
SAMPLED BY: BRENDON WOLF/VOK
SAMPLE ID: EFFLUENT

GTA PROJECT NO: 010422-2
GTA SAMPLE NO: 2
DATE RECEIVED: 1/4/2022
TIME RECEIVED: 11:54 AM
DATE SAMPLED: 1/4/2022
TIME SAMPLED: 7:18 AM
SAMPLE MATRIX: WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
AMMONIA-N EPA 350.1	5.1	0.030	mg/L (PPM)	KC	1/4/2022
CHLORIDE EPA 300.0	460	10	mg/L (PPM)	TR	1/5/2022
NITRATE-N EPA 300.0	0.74	0.10	mg/L (PPM)	TR	1/5/2022
NITRITE-N EPA 300.0	<0.10	0.10	mg/L (PPM)	TR	1/5/2022
SODIUM DISS EPA 200.8	480	5.0	mg/L (PPM)	MR	1/11/2022
TOTAL PHOSPHORUS EPA 365.2	0.17	0.010	mg/L (PPM)	KC	1/4/2022

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED

830 Robinwood Court
Traverse City, MI 49686
Phone (231) 929-0905 Fax (231) 929-0894

Chain of Custody Record

[illegible]