

**INDEPENDENT TESTING LAB**

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

[www.gtanalytical.com](http://www.gtanalytical.com)

Company: VILLAGE OF KALKASKA  
Name:  
ClientProj:

Site Addr: 1005 ISLAND LAKE RD

GTA ProjNo: 010825-2

KALKASKA  
Sampled By: BRENDON WOLF/IAI  
Date Rec: 1/8/2025  
Time Rec: 2:21 PM

| Sample No. | Sample ID       | Date Sampled | Time Sampled | Sample Matrix |
|------------|-----------------|--------------|--------------|---------------|
| 1          | EFFLUENT WEEK 1 | 1/2/2025     | 11:55 AM     | WATER         |
| 2          | EFFLUENT WEEK 2 | 1/7/2025     | 8:35 AM      | WATER         |

ELECTRONIC SIGNATURE REPORT. This is a final report for the following pages of data for the samples specified above. All analysis was performed by the methods stated and all quality control measures required were completed. All quality control information is available upon request.

*Kirk Chase*

Kirk L. Chase/Chemist  
Grand Traverse Analytical  
830 Robinwood Court  
Traverse City, MI 49686  
Ph: 231-929-0905  
Fx: 231-929-0894  
SP: 231-590-0291  
[kirk@gtanalytical.com](mailto:kirk@gtanalytical.com)



## INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY: VILLAGE OF KALKASKA

GTA PROJECT NO: 010825-2

PROJECT NO:

GTA SAMPLE NO: 1

LOCATION: 1005 ISLAND LAKE RD

DATE RECEIVED: 1/8/2025

TIME RECEIVED: 2:21 PM

KALKASKA

DATE SAMPLED: 1/2/2025

MI

TIME SAMPLED: 11:55 AM

SAMPLED BY: BRENDON WOLF/IAI

SAMPLE MATRIX: WATER

SAMPLE ID: EFFLUENT WEEK 1

### SAMPLE ANALYSIS

| <u>Analysis</u>    | <u>Concentration</u> | <u>LOD</u> | <u>Units</u> | <u>Analyst</u> | <u>Date Completed</u> |
|--------------------|----------------------|------------|--------------|----------------|-----------------------|
| CALCIUM EPA 200.8  | 50                   | 5.0        | mg/L (PPM)   | MR             | 1/9/2025              |
| CHLORIDE EPA 300.0 | 280                  | 10         | mg/L (PPM)   | KC/TR          | 1/10/2025             |
| SODIUM EPA 200.8   | 130                  | 5.0        | mg/L (PPM)   | MR             | 1/9/2025              |

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED



## INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY: VILLAGE OF KALKASKA

GTA PROJECT NO: 010825-2

PROJECT NO:

GTA SAMPLE NO: 2

LOCATION: 1005 ISLAND LAKE RD

DATE RECEIVED: 1/8/2025

TIME RECEIVED: 2:21 PM

KALKASKA

DATE SAMPLED: 1/7/2025

MI

TIME SAMPLED: 8:35 AM

SAMPLED BY: BRENDON WOLF/IAI

SAMPLE MATRIX: WATER

SAMPLE ID: EFFLUENT WEEK 2

### SAMPLE ANALYSIS

| <u>Analysis</u>    | <u>Concentration</u> | <u>LOD</u> | <u>Units</u> | <u>Analyst</u> | <u>Date Completed</u> |
|--------------------|----------------------|------------|--------------|----------------|-----------------------|
| CHLORIDE EPA 300.0 | 430                  | 10         | mg/L (PPM)   | KC/TR          | 1/10/2025             |
| SODIUM EPA 200.8   | 330                  | 50         | mg/L (PPM)   | MR             | 1/9/2025              |

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED

830 Robinwood Court  
Traverse City, MI 49686  
Phone (231) 929-0905 Fax (231) 929-0894

## Chain of Custody Record

[illegible]