

**INDEPENDENT TESTING LAB**

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

Company: VILLAGE OF KALKASKA

Name:

ClientProj: WEEKLY/MONTHLY

GTA ProjNo: 052925-6

Site Addr: 1005 ISLAND LAKE RD

KALKASKA

Sampled By: BRENDON WOLF/IAI

Date Rec: 5/29/2025

Time Rec: 2:35 PM

Sample No.	Sample ID	Date Sampled	Time Sampled	Sample Matrix
1	EFFLUENT WEEK 4	5/19/2025	8:35 AM	WATER
2	MANHOLE P 11	5/23/2025	1:42 PM	WATER
3	MANHOLE C122	5/23/2025	1:25 AM	WATER
4	MANHOLE C32	5/23/2025	2:15 AM	WATER
5	EFFLUENT WEEK 5	5/27/2025	1:25 PM	WATER

ELECTRONIC SIGNATURE REPORT. This is a final report for the following pages of data for the samples specified above. All analysis was performed by the methods stated and all quality control measures required were completed. All quality control information is available upon request.

Kirk Chase

Kirk L. Chase/Chemist
Grand Traverse Analytical
830 Robinwood Court
Traverse City, MI 49686
Ph: 231-929-0905
Fx: 231-929-0894
SP: 231-590-0291
kirk@gtanalytical.com



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY:	VILLAGE OF KALKASKA	GTA PROJECT NO:	052925-6
PROJECT NO:	WEEKLY/MONTHLY	GTA SAMPLE NO:	1
LOCATION:	1005 ISLAND LAKE RD	DATE RECEIVED:	5/29/2025
	KALKASKA	TIME RECEIVED:	2:35 PM
	MI	DATE SAMPLED:	5/19/2025
SAMPLED BY:	BRENDON WOLF/IAI	TIME SAMPLED:	8:35 AM
SAMPLE ID:	EFFLUENT WEEK 4	SAMPLE MATRIX:	WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
CHLORIDE EPA 300.0	280	10	mg/L (PPM)	KC/TR	6/2/2025
SODIUM EPA 200.8	160	12	mg/L (PPM)	MR	6/11/2025

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY:	VILLAGE OF KALKASKA	GTA PROJECT NO:	052925-6
PROJECT NO:	WEEKLY/MONTHLY	GTA SAMPLE NO:	2
LOCATION:	1005 ISLAND LAKE RD	DATE RECEIVED:	5/29/2025
	KALKASKA	TIME RECEIVED:	2:35 PM
	MI	DATE SAMPLED:	5/23/2025
SAMPLED BY:	BRENDON WOLF/IAI	TIME SAMPLED:	1:42 PM
SAMPLE ID:	MANHOLE P 11	SAMPLE MATRIX:	WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
CHLORIDE EPA 300.0	49	10	mg/L (PPM)	KC/TR	6/2/2025
SODIUM EPA 200.8	19	12	mg/L (PPM)	MR	6/11/2025

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY: VILLAGE OF KALKASKA

PROJECT NO: WEEKLY/MONTHLY

LOCATION: 1005 ISLAND LAKE RD

KALKASKA
MI

SAMPLED BY: BRENDON WOLF/IAI

SAMPLE ID: MANHOLE C122

GTA PROJECT NO: 052925-6

GTA SAMPLE NO: 3

DATE RECEIVED: 5/29/2025

TIME RECEIVED: 2:35 PM

DATE SAMPLED: 5/23/2025

TIME SAMPLED: 1:25 AM

SAMPLE MATRIX: WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
CHLORIDE EPA 300.0	150	10	mg/L (PPM)	KC/TR	6/2/2025
SODIUM EPA 200.8	58	12	mg/L (PPM)	MR	6/11/2025

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY:	VILLAGE OF KALKASKA	GTA PROJECT NO:	052925-6
PROJECT NO:	WEEKLY/MONTHLY	GTA SAMPLE NO:	4
LOCATION:	1005 ISLAND LAKE RD	DATE RECEIVED:	5/29/2025
	KALKASKA	TIME RECEIVED:	2:35 PM
	MI	DATE SAMPLED:	5/23/2025
SAMPLED BY:	BRENDON WOLF/IAI	TIME SAMPLED:	2:15 AM
SAMPLE ID:	MANHOLE C32	SAMPLE MATRIX:	WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
CHLORIDE EPA 300.0	100	10	mg/L (PPM)	KC/TR	6/2/2025
SODIUM EPA 200.8	36	12	mg/L (PPM)	MR	6/11/2025

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED



INDEPENDENT TESTING LAB

830 ROBINWOOD COURT, TRAVERSE CITY, MI 49686

PH: 231-929-0905

FAX: 231-929-0894

www.gtanalytical.com

COMPANY:	VILLAGE OF KALKASKA	GTA PROJECT NO:	052925-6
PROJECT NO:	WEEKLY/MONTHLY	GTA SAMPLE NO:	5
LOCATION:	1005 ISLAND LAKE RD	DATE RECEIVED:	5/29/2025
	KALKASKA	TIME RECEIVED:	2:35 PM
	MI	DATE SAMPLED:	5/27/2025
SAMPLED BY:	BRENDON WOLF/IAI	TIME SAMPLED:	1:25 PM
SAMPLE ID:	EFFLUENT WEEK 5	SAMPLE MATRIX:	WATER

SAMPLE ANALYSIS

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>
CHLORIDE EPA 300.0	230	10	mg/L (PPM)	KC/TR	6/2/2025
SODIUM EPA 200.8	140	12	mg/L (PPM)	MR	6/11/2025

ND = NOT DETECTED, RESULT < LOD

LOD = LIMIT OF DETECTION

s.u. = STANDARD pH UNITS REPORTED AT 25 C

DISS = DISSOLVED

830 Robinwood Court
Traverse City, MI 49686
Phone (231) 929-0905 Fax (231) 929-0894

Chain of Custody Record

[illegible]